

**Date:** April 14, 2015 **Completed By:** Wade Balon**Pretest****Test Completed for:** MBB Properties Inc. c/o of NAI Eckville Real Estate Holdings Ltd (Daniel Goldstrom)**Billing LSD:** NW 21 39 3 W5**Landowner Name:** NAI ADVENT (ECKVILLE LAST HILL GOLF COURSE)**Landowner Address:** 833 34TH AVE SE CALGARY, AB**Postal Code:** T2G 4Y9**Landowner Phone #:** H/W: 403-984-6300 C: 403-809-8326**Landowner LSD:** NW 21 39 3 W5**Driving Directions from Alken shop:** West to Hwy 766, South to Last Hill Road, West 1 mile, ¼ mile south**Static Level:** 17.08 Metres **GPS:** N52 22.024 W114 22.053**Pump Type:** SUBMERSIBLE **H.P.:** 5 **Voltage:** 480**Measurement Taken From:** TOP OF CASING **Casing:** 5 ½"**Water Sample Taken From:** LINE FROM PUMP **Outside Temperature:** 2C**Pitless Adaptor or Well Seal :** DICKSON ADAPTER **Weather:** OVERCAST**Well Depth:** ~32 M **Year Drilled:** UNKNOWN **Well Used For:** DUG OUT**Remarks:** Pump was not working. Mice made a nest and chewed through wires. Line going into dugout frozen.*Lifted pitless for test. Well pumped at 50 GPM for 1 hr. Water had iron and red colour but quickly cleared. Static level only dropped 1.2M after 60 min. Well recovered within 1 inch after 1 hour of recovery.*

TIME	STATIC LEVEL in Metres	FLOW RATE Gallons per Minute	DRAWDOWN in Metres	RECOVERY LEVEL in Metres	RECOVERY RATE in Metres
START:	17.08	0.00	0.00	18.28	0.00
1 MIN:	18.00	50.00	0.92	17.27	-1.01
2 MIN:	18.06	50.00	0.06	17.24	-0.03
3 MIN:	18.07	50.00	0.01	17.22	-0.02
4 MIN:	18.08	50.00	0.01	17.20	-0.02
5 MIN:	18.09	50.00	0.01	17.20	0.00
10 MIN:	18.13	50.00	0.04	17.17	-0.03
20 MIN:	18.16	50.00	0.03	17.13	-0.04
30 MIN:	18.20	50.00	0.04	17.13	0.00
60 MIN:	18.28	50.00	0.08	17.11	-0.02
70 MIN:					